



CARROLL COUNTY FIRE RESCUE

501 Old Newnan Road • Carrollton, Georgia 30117

P.O. Box 338 • Carrollton, Georgia 30112

Phone: 770.830.5880 • Fax: 770.830.5984

www.carrollcountyga.com

Dave Wade
Deputy Chief

Chuck Barnwell
Fire Chief

David Harmon
Fire Marshal

Fire Marshal's Office Temporary Consumer Fireworks Stand/Tent Fire Inspection Checklist

Temporary Consumer Fireworks Stands/Tents shall be erected/constructed, stocked with product, and ready for sale before a fire inspection from the Fire Marshal's Office can occur. After a successful fire inspection has been completed then a Temporary Fireworks Stand Permit will be issued. The permit is no longer valid after the expiration date or if the location of the stand changes during the permitted time frame. The following items will be inspected by the fire inspector:

1. Adequate exits
2. "No Smoking" signs posted, all sides
3. "18-year-old to purchase" sign prominently posted
4. Lighting and electrical up to fire code
5. Fire Extinguisher(s) (minimum (1) 4A rating)
6. Generator & gasoline approved storage
7. Verify operator's state fireworks license
8. Verify Date of Birth of fireworks stand staff
9. On site storage of stock
10. Trash storage/removal
11. Verify "Permissible" fireworks only
12. Quantity of fireworks
13. Stand adequately constructed and anchored
14. Clearance to public way (25') and inhabited buildings (50')
15. 25' Clearance around stand of ignition sources and combustible materials

To schedule an inspection, visit the Carroll County Website at www.carrollcountyga.com.

Select Fire Rescue from the Government drop down section. Once on the Fire Rescue homepage you'll find a link on the right-hand side to Request an Inspection. The Carroll County Fire Marshal's Office requires a 5-day notice in advance of the requested inspection date.